



Product Service

Attestation of Conformity

No. N8 10 09 71883 002

Holder of Certificate: SEGI BIZ CO.,LTD

129-11, Gamjeon-dong, Sasang-gu
Busan 617-050
REPUBLIC OF KOREA

Product:

**Joint boxes
Joint Box (PIN-BOX)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

CPSA0111010

Date, 2010-09-29

(James Jeon)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2

ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ CERTIFICAT ◆ ЗЕРТИФИКАТ ◆ 認証証書 ◆ CERTIFICATE ◆ ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ CERTIFICAT ◆ ЗЕРТИФИКАТ ◆ 認証証書 ◆



Product Service

Attestation of Conformity
No. N8 10 09 71883 002

Model(s): SG-TB-20P, SG-TB-30P, SG-TB-20PT, SG-TB-15P,
 SG-TB-15PT, SG-TB-10P, SG-TB-10P15, SG-TB-6PT,
 SG-TB-6P15, SG-TB-4PT, SG-TB-4P15

Parameters:	Type:	Screw-type
	Number of terminals:	Multi way
	Rated connection capacity:	0.5-2.5 mm ²
	Rated voltage:	250 V a.c.
	Rated current:	15 A
	Type of connector:	Rigid
	Degree of protection against ingress of liquids:	IPX0 (SG-TB-20P, SG-TB-30P, SG-TB-20PT, SG-TB-15P, SG-TB-15PT, SG-TB-10P15, SG-TB-6PT, SG-TB-6P15, SG-TB-4PT, SG-TB-4P15) IP65 (only for SG-TB-10P)

Remark: The protection against accidental contact must be guaranteed by installation.

Tested according to: EN 60998-1:2004
 EN 60998-2-1:2004